

## **GOVERNMENT OF TELANGANA** STATE DISASTER RESPONSE & FIRE SERVICES DEPARTMENT



From

The District fire officer,

Malkajgiri Division.

To, DR N.B.SUDERSHAN, LEAD INDIA BHARATRATNAS SCHOOL, sy.no.77, 79.BANDLAGUDA(V), KEESARA(M), MEDCHEL (D), HYDERABAD,

	TELANGANA STATE.,	
7.	Ack. No.384870002021 Dated:23/04/2021	
Sir,		
Sub:	TELANGANA STATE DISASTER RESPONSE & FIRE SERVICE DEPARTMENT –Malkajgiri Division. Renewal of No Objection Certificate for Occupancy to the Non Multi storeyed Building of LEAD INDIA BHARATRATNAS SCHOOL, LEAD INDIA BHARATRATNAS SCHOOL, Sy.no. 77,78,79.BANDLAGUDA(V), KEESARA(M), MED CHEL (D), HYDERABAD, TELANGANA STATE./-Ahmedguda/Keesara/Medchal, – Regarding.	
Ref:	1. Acknowledgement No 384870002021 2. This Office NOC for Occupancy Ack/RC No.1346 dt.23/04/2021 3. Non Multi storeyed Building Inspection Committee Report,. Ack. No. 384870002021, dt. 23/04/2021	



The Non Multi storeyed Building Inspection committee, vide reference cited (3) has inspected the Non Multi storeyed Building of LEAD INDIA BHARATRATNAS SCHOOL, LEAD INDIA BHARATRATNAS SCHOOL, sy.no.77,78,79.BANDLAGUDA(V), KEESARA(M), MEDCHEL (D), HYDERABAD, TELANGANA STATE./-Ahmedguda/Keesara/Medchal

\*\*\*\*\* \*\*\*\*

- The above said building was issued was issued No Objection certificate vide reference cited (2) for Non Multi storeyed Building with 1 Ground, 3 Floors, with a height of 12.00 Meters for EDUCATIONAL B-1 Schools up to senior secondary level Occupancy.
- 3) Now the Builder/Authorized person has requested to issue Renewal of No Objection Certificate for Occupancy to the Non Multi storeyed Building with 1 Ground, 3 Floors, with a height of 12.00 Meters for EDUCATIONAL B-1 Schools up to senior secondary level Occupancy

4) Open Spaces: The builder provided the following open spaces all around the building.

Sl.No	Side	Inon amagas BT	
a 1	North	Open spaces as per Noc occupancy	Open spaces provided now
2	South	0.00	30.00
3	East	2.00	2.00
4	West	6.00	23.60
b Sl. No	Gate Width A - 0	6.00	20.40
1	LIIU V VAID WINDER		provided now
2	Entry Gate Head Clearance	4.50	6
3	Exit Gate Width	5.00	5
4	Exit Gate Head Clearance	4.50	6
	Tread Clearance	5.00	5.00

No.	Item / Description	as per Noc occupancy	provided
	Farthest point (Most Remote Point) With in a storey or a mezzanine floor to the door to an Exit.	28.00	28.00
	The Dead end of the corridor length in exit access. (6 mtrs for Educational, Institutional and Assembly, 15mtrs for other Occupancies)	6.00	6.00

6) Stair Cases (As per Occupancy NOC):

Sl.no.	Type of staircases	Total width	No of staircases	Floors from	Floors to
1	Internal staircases	1.20	1	Ground	Terrace
2	External staircases	2.00	1	Ground	Terrace

7) Means of Escape Floor Wise Details:

Sl.no	Floor type	Buil-up Area in Sq.Mtrs	Type of Occupancy		Means of escape required as per Occupancy NOC	Means escape available now
1	Groun		EDUCATIONAL B-1 Schools up to senior secondary level	111.00	2.23	6.00
2	1st Floor	445.50	EDUCATIONAL B-1 Schools up to senior secondary level	111.00	2.23	3.20
3	2nd Floor	445.50	EDUCATIONAL B-1 Schools up to senior secondary level	111.00	2.23	3.20
4	3rd Floor	175.00	RESIDENTIAL A-3 Dormitories	14.00	0.28	3.20

8) Fire Shaft as per Occupancy NOC:

9) Floor Wise details of Fire Fighting Installations:

	Floor Details	Fire Extinguish er		Automatic Sprinklers System	Manually Operated Electronic Fire Alarm System	Automatc detection and alarm system
1	Ground	3.00	1.00	0.00	0.00	0.00
2	1st Floor	3.00	1.00	0.00	0.00	0.00
3	2nd Floor	3.00	1.00	0.00	0.00	0.00
4	3rd Floor	1.00	1.00	0.00	1.00	2.00

10) Fire Fighting Installations As per Occupancy NOC:

Fire Fighting System.	Required As per Occupancy NOC	Provided
-----------------------	-------------------------------	----------

11). The Non Multi storeyed Building Inspection Committee have reported that the Management has provided the Fire Safety Measres and there is no deficiencies.

12. Remarks:

As per recommendations of inspection committee, the issue of Renewal of NOC for Occupancy is approved.

13) In view of the above and as per recommendations of the Non Multi storeyed building inspection Committee, the Renewal of No Objection Certificate for occupancy is issued to Non Multi storeyed Building with LEAD INDIA

BHARATRAS SCHOOL, LEAD INDIA BHARATRAS

SCHOOL, sy.no.77,78,79.BANDLAGUDA(V), KEESARA(M), MEDCHEL (D), HYDERABAD, TELANGANA

STATE./-Ahmedguda/Keesara/Medchal

with a height of 12.00 Meters for EDUCATIONAL B-1 Schools up to senior secondary level Occupancy subject to the following conditions

Sl No Builder and Management Body	Occupant	Management Body and fire and security personnel
-a) All the fire protection	All the escape/exit roots shall	All the occupants must know the correct

1	arrange	ements shall be maintained		
1	in good inspect -b) Do's shall be entire b	d condition as seen during ion.	not be kept locked/blocked or encroached	method of operation of the fire fighting systems installed.
2	non-function measures ar	ning of fire safety nd other installations shall onsibility of the	TO 040 1 11 0	Mock drills should be conducted once in 3 months for initial two years. Thereafter, once in every 6 months.
3	Addition / a building ma authority.	ay be verified by building	conducted once in 3 months for initial two years.	All security personnel shall be trained to operate the fire safety equipment during emergency and guiding the occupants in safe evacuation. Call the fire Brigade by dialing 101.
4	occupancy i	jection Certificate for is valid for Five year from issue of this letter.	evacuate the area completely	Attack the fire using available fire equipment only if you feel capable of controlling it. If not, take all steps to isolate the area by closing doors and windows.

This Renewal of No Objection Certificate for Occupancy is valid for Five years from the date of issue of this letter. It is the responsibility of the builder to apply for renewal NOC, duly remitting the user charges as per G.O. Ms. No. 71, Home (Prison – A) Department, dated 01-04-2010, two months before expiry of this No Objection Certificate.

Yours Sincerely, District fire officer, Malkajgiri Division.

## Copies to:

- i) The Management
- ii) Non Multi storeyed Building Inspection Committee
- iii) Copy submitted to Regional Fire officer
- iv) Copy submitted to DG fire services

"THIS IS COMPUTER GENERATED DOCUMENT AND DO NOT REQUIRE ANY STAMP OR SIGNATURE"

For Lead India Bharat Ratnas School

Authorized Signatory